

ATTESTATION OF CONFORMITY

No.2123769.03

Applicant: Kabelbedrijven Draka Nederland B.V.
Hamerstraat 2-4
1021 JV Amsterdam, The Netherlands

Manufacturer: Kabelbedrijven Draka Nederland B.V.
Hamerstraat 2-4
1021 JV Amsterdam, The Netherlands

Product: Signal cables PH90 (FB90), silicone rubber insulated, types:
2301 (1x2x0,8 mm) 2302Q (1x4x0,8 mm) 2302 (2x2x0,8 mm)
2304 (4x2x0,8 mm) 2308 (8x4x0,8 mm) 2312 (12x2x0,8 mm)
2316 (16x2x0,8 mm) 2320 (20x2x0,8 mm) 2330 (30x20x0,8 mm)
2301.150 (1x2x1,5 mm²) 2301.250 (1x2x2,5 mm²)
2302.150 (2x2x1,5 mm²) 2302.250 (2x2x2,5 mm²)

Performance requirements: NEN-EN 50200: June 2006
Methode of test resistance to fire of unprotected smal cables for use in
emergency circuits ($\varnothing \leq 20$ mm)

Testdate: 16 and 17 February 2009


Classification: **The cables belong to class PH90 (FB90)**

This Attestation is granted on account of tests made the laboratory of Draka Kabel B.V. in Amsterdam, the results of which are laid down in KEMA file: no. 212376900.

The tests have been carried out on one single specimen of the product, submitted by the manufacturer. The Attestation does not include an assesment of the manufacturer's production. Conformity of his production with the specimen tested by KEMA is not the responsibility of KEMA.

This Attestation of Conformity is valid till 29 April 2012.

KEMA Quality B.V.
Arnhem, 29 April 2009



H.R.M. Barends
Certification Manager